



0000166119

GREEN ACRES WATER COMPANY
4743 E 30TH PLACE
YUMA, AZ 85365
928.341.9685

RECEIVED

2015 SEP 15 A 11:32

AZ CORP COMMISSION
DOCKET CONTROL

ARIZONA CORPORATION COMMISSION
DOCKET CONTROL
1200 W WASHINGTON ST
PHOENIX, AZ 85007

AUGUST 31, 2015

RE: DOCKET NO W-02271A-14-0265 / DECISION 74824

ATTACHED IS RESPONSE TO COMPLIANCE ITEM FOR THIS DOCKET A REVISED RATE SCHEDULE
REFLECTING THE EMERGENCY RATE INCREASE AND A SCHEDULE OF RATES AND CHARGES, INCLUDING
THE REPAIR SURCHARGE.

ALSO ATTACHED IS A CROSS CONNECTION OR BACKFLOW TARIFF.

THANK YOU

DAWN SIMPSON
GREEN ACRES WATER COMPANY

Arizona Corporation Commission
DOCKETED

SEP 15 2015

DOCKETED BY

ORIGINAL

TARIFF SCHEDULE

EMERGENCY RATES

UTILITY: GREEN ACRES WATER COMPANY
Docket No: W-02271A-14-0265

Decision No: 74824
Effective: December 1, 2014

MONTHLY CHARGES:

Residential:

5/8 x 3/4-Inch METER \$17.50

REPAIR SURCHARGE \$17.19

COMMODITY CHARGE (ALL CLASSES):

1 TO 3,000 GALLONS \$1.00

OVER 3,000 GALLONS \$2.00

SERVICE LINE AND METER INSTALLATION CHARGES:

5/8 X 3/4" METER \$100.00

3/4" METER \$120.00

1" METER \$160.00

1 1/2" METER \$300.00

2" METER \$400.00

SERVICE CHARGES:

ESTABLISHMENT \$20.00

ESTABLISHMENT (AFTER HOURS) NT

RECONNECTION (DELINQUENT) \$5.00

AFTER HOURS CHARGE (FLAT RATE) NT

METER TEST \$25.00

DEPOSIT \$75.00

DEPOSIT INTEREST (R14-2-403.B.3) *

RE-ESTABLISHMENT (WITHIN 12 MONTHS) \$25.00

RE-ESTABLISHMENT (WITHIN 12 MONTHS AFTER HRS) NT

NSF CHECK NT

DEFERRED PAYMENT – PER MONTH NT

METER RE-READ \$2.50

LATE PAYMENT PENALTY 10.00%

MOVING CUSTOMER METER (CUSTOMER REQUEST) NT

AFTER HOURS SERVICE CHARGE (RULE R14-2-403.D) NT

NT=NO TARIFF

*PER COMMISSION RULE ACC R14-2-403.B.3

Company Name: Green Acres Water Co Page 1 of 2**CROSS-CONNECTION OR BACKFLOW TARIFF****PURPOSE:**

The purpose of this tariff is to protect Green Acres Water Company ("Company") water from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises by requiring the installation and periodic testing of backflow-prevention assemblies pursuant to the provisions of the Arizona Administrative Code ("A.A.C.") R14-2-405.B.6 and A.A.C. R18-4-215.

REQUIREMENTS:

In compliance with the Rules of the Arizona Corporation Commission ("Commission") and the Arizona Department of Environmental Quality ("ADEQ"), specifically A.A.C. R14-2-405.B.6 and A.A.C. R18-4-215 relating to backflow prevention:

1. The Company may require a customer to pay for and to have installed a backflow-prevention assembly if A.A.C. R18-4-215.B or C applies.
2. A backflow-prevention assembly required to be installed by the customer under Paragraph 1 of this tariff shall comply with the requirements set forth in A.A.C. R18-4-215.D and E.
3. Subject to the provisions of A.A.C. R14-2-407 and 410, and in accordance with Paragraphs 1 and 7 of this tariff, the Company may terminate service or may deny service to a customer who fails to install a backflow-prevention assembly as required by this tariff
4. The Company shall give any existing customer who is required to install a backflow-prevention assembly written notice of said requirement. If A.A.C. R14-2-410.B.1.a. is not applicable, the customer shall be given thirty (30) days from the time such written notice is received in which to comply with this notice. If the customer can show good cause as to why he cannot install the backflow-prevention assembly within thirty (30) days, the Company or Commission Staff may suspend this requirement for a reasonable period of time.

****FOR OFFICIAL USE ONLY****

Effective Date: _____

DECISION NO. 74824

Company Name: Green Acres Water Company Page 2 of 2

5. Testing shall be in conformance with the requirements of A.A.C. R18-4-215.F. The Company may require the customer to pay to have the backflow-prevention assembly tested as long as the Company does not require an unreasonable number of tests.
6. The customer shall provide the Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:
 - a. assembly identification number and description;
 - b. location
 - c. date(s) of test(s);
 - d. description of repairs and recommendations for repairs made by tester; and
 - e. the tester's name and certificate number.
7. In the event the backflow-prevention assembly does not function properly or fails any test, and an obvious hazard as contemplated under A.A.C. R14-2-410.B.1.a. exists, the Company may terminate service immediately and without notice. The backflow-prevention assembly shall be repaired or replaced by the customer and retested.
8. In the event the backflow-prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirement, and A.A.C. R14-2-410.B.1.a. is not applicable, the backflow-prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or dysfunction of the assembly, or failure to retest, shall be grounds for termination of water service in accordance with A.A.C. R14-2-410.

****FOR OFFICIAL USE ONLY****

Effective Date: _____

DECISION NO. 74824